

Product certificate K82446/01

Issued 2014-08-01

Replaces

Page 1 of 3

Butterfly valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by


E. Hawle Armaturenwerke GmbH

complying with the technical specifications as laid down in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate, on delivery, may be relied upon to comply with Kiwa evaluation guideline

BRL-K602/04: "Valves and other accessories for drinking water transport and drinking water distribution systems"

which covers the requirements of

EN 1074/2:2000 "Valves for water supply - Fitness for purpose requirements and appropriate verification tests – Part 2: Isolating valves".



Bouke Meekma
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 70 414 44 00
Fax +31 70 414 44 20
info@kiwa.nl
www.kiwa.nl



Supplier

E. Hawle Armaturenwerke
GmbH
Wagrainer Straße 13
4840 VÖCKLABRUCK
Austria
Tel. +43 7672/725760
Fax +43 7672/78464
hawle@hawle.at
www.hawle.at

Certification process
consists of initial and
regular assessment of:

- quality system
- product

Butterfly valves

Product specification

The products mentioned below belong to this certificate

Type 9881 and Type 9881K, PN 10 and PN16, manually operated

DN 150
DN 200
DN 250
DN 300
DN 350
DN 400
DN 450
DN 500
DN 600
DN 700
DN 800
DN 900
DN 1000
DN 1100
DN 1200

Butterfly valves

Application and use

The products are intended for use, above and below ground, in drinking water transport and drinking water distributions system supply lines intended for human consumption.

Toxicological requirements

Approval:



This product is approved on the basis of the requirements set in the "Regeling materialen en chemicaliën watervoorziening" (Regulation materials and chemicals drinking water and warm tap water supply"; published in the Government Gazette).

ATA criteria:

The ATA product certification is based on two main criteria. It shall permanently comply with:

- The product recipe approved during the assessment procedure. The recipe is laid down in the for confidentiality reasons undisclosed appendix ATA to certificate K82446 This recipe is not to be changed without prior approval by Kiwa according to the Kiwa-ATA-approval procedure;
- Specific ATA-product requirements, laid down in appendix ATA to certificate K82446. For confidentiality reasons this appendix ATA is not public.

Marking

The Kiwa[®]-mark products are marked with the word mark "KIWA" together  with or the abbreviated word mark  . The fittings shall be provided with at least the following marks:

Compulsory specifications:

- name or mark of manufacturer: on the body or specification plate;
- identification of the shell material(s): on the body or specification plate;
- nominal size "DN ...": on the body or specification plate;
- nominal working pressure "PN ...": on the body or specification plate;
- identification of the year of manufacture: on the body or specification plate.

Method of marking:

- Non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- E. Hawle Armaturenwerke GmbH
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.